



Align the CHP flush at the front and at the sides with a distance of 50 or 90 mm to the vibration damping plate.

a = Spring block element 3150433

Back = B (see detail C)

The spring elements are attached to the foundation on site.

Pos.	Item No.	rev.	Title	Qty
	3241101	00	Positioning CHP unit 50.0 kW (eU) on vibration damping plate	
1	3191069	00	Vibration damping plate 50.0 kW RAL 7016	1
2	3070459	00	Countersunk head screw ISO 10642 M12 x 30 8.8 vz	6
3	3240617	00	Spring block element set 50.0 kW (eU)	1

ATTENTION: Unwinding data is for information purposes only! Information on outer dimensions and bending allowances do not dismis the checker from inspection!		Tolerances according to:		weight: 2103,72 kg	scale: 1:15	particularity:
				title: Positioning CHP unit 50.0 kW (eU) on vibration damping plate		
		This drawing must not be copied, forwarded, reproduced or otherwise used in any other way.		part number: 3241101	raw part number:	sheet: 1
				current index:	material thickness:	

1:40