

Product designation		17.0	21.0	25.0	30.0
Technical data					
Rated output - electrical ⁽¹⁾	kW _{el}	17,0	21,0	25,0	30,0
Rated output - thermal ⁽²⁾	kW _{th}	40,4	46,6	51,8	57,8
Power modulation - electrical	kW _{el}	10,0 - 17,0	10,0 - 21,0	12,5 - 25,0	15,0 - 30,0
Power modulation - thermal	kW _{th}	30,6 - 40,4	30,6 - 46,6	33,4 - 51,8	37,3 - 57,8
Gas connection power	kW _{Hi}	60,21	70,66	80,29	95,59
Liquefied Petroleum gas input	kg/h	4,68	5,49	6,24	7,43
Liquefied Petroleum gas input	l/h	8,66	10,17	11,55	13,75
CHP coefficient		0,42	0,45	0,48	0,52
f Primary energy factor ⁽³⁾		0,462	0,407	0,353	0,366
PES	%	25,7	26,8	27,7	25,6
ErP energy efficiency label ⁽⁴⁾		A++	A++	A++	A++
Sound pressure level L _{pA} ⁽⁵⁾	dB(A)	55	57	57	59
Sound power level L _{WA}	dB(A)	70	72	72	75
Maintenance interval	op. hrs.	10.000	8.000	8.000	8.000
Efficiency ratios					
Electrical efficiency ratio η_{el}	%	28,2	29,7	31,1	31,4
Thermal efficiency ratio η_{th}	%	67,1	65,9	64,6	60,5
Total efficiency ratio η_{total}	%	95,3	95,6	95,7	91,8
Heat extraction					
Flow temperature ± 5 °C	°C	80	80	80	80
Return flow temperature ± 5 °C	°C	25-65	25-65	25-65	25-65
min./max. ambient temperature	°C	5/30	5/30	5/30	5/30
Pressure rating - water side	PN	3	3	3	3
Electrical energy generation					
Nominal voltage	V	400	400	400	400
Frequency	Hz	50	50	50	50
Nominal effective power PnG	kW _{el}	17,0	21,0	25,0	30,0
Apparent power S _{E max}	kVA	23,9	27,6	32,1	37,0
Nominal voltage UnG	V	400	400	400	400
Frequency	Hz	50	50	50	50
Cos ϕ uncompensated		0,71	0,76	0,78	0,81
Reactive power compensation ⁽⁶⁾	kVar	10,40	10,40	13,87	13,87
Number of steps		1	1	1	1
Degree of choking or resonance frequency		-	-	-	-
Cos ϕ acc. to VDE-AR-N 4105 quadrants II, III ⁽⁶⁾		0,95	0,95	0,95	0,95
Rated alternating current I _r	A	34,6	39,9	46,3	53,5
Rated alternating current I _r cos ϕ 1	A	24,5	30,3	36,1	43,3
Rated apparent power S _{rE}	kVA	23,9	27,6	32,1	37,0
Short-circuit alternating current Alternator I _k "	A	358,1	358,1	358,1	358,1
Grid short circuit power with UnG S _k "	kVA	185,0	185,0	185,0	185,0
Start-up current I _k approx.	A	59	59	59	59
Motor					
Motor manufacturer		YANMAR	YANMAR	YANMAR	YANMAR
Number of cylinders		4	4	4	4
Displacement	l	3,3	3,3	3,3	3,3
Air-fuel ratio λ		1,0	1,0	1,0	1,0
Engine oil - RMB/ENGINE Oil	l	90	90	90	90

Product designation		17.0	21.0	25.0	30.0
Generator					
Generator manufacturer		EMOD	EMOD	EMOD	EMOD
Generator type		asynchronous	asynchronous	asynchronous	asynchronous
Motor start-up		provided	provided	provided	provided
Speed	rpm	1.530	1.530	1.530	1.530
Supply and exhaust air					
Combustion air requirement	m ³ /h	77	90	103	122
Module ventilation flow rate	m ³ /h	260	260	260	260
Total air requirement of module	m ³ /h	337	350	363	382
Permissible counter-pressure of exhaust air system max. ⁽⁷⁾	Pa	150	150	150	150
min./max. intake air temperature	°C	5/30	5/30	5/30	5/30
Min. cross section without hydraulic resistance	cm ²	650	650	650	650
Flue gas					
Flue gas temperature ⁽⁸⁾ / max.	°C	55 / < 110	55 / < 110	55 / < 110	55 / < 110
Flue gas mass flow rate - damp	kg/h	81	95	108	129
Flue gas volume flow - dry	Nm ³ /h	66	77	87	104
Delivery pressure flue gas max.	Pa	500	500	500	500
Delivery pressure flue gas cascades max.	Pa	500	500	500	500
Delivery pressure max. for flue gas and exhaust air combination	Pa	150	150	150	150
Emissions Nox	mg/kWh	< 240	< 240	< 240	< 240
Dimensions & weight					
Dimensions of module L x W x H	mm	1.778x759x1.403	1.778x759x1.403	1.778x759x1.403	1.778x759x1.403
Weight approx. (including operating resources)	kg	1.038	1.038	1.038	1.038
ErP-Label					
ErP energy efficiency label ⁽⁴⁾		A++	A++	A++	A++
ErP energy input ⁽⁴⁾	kWh _{HS}	66,83	78,43	89,12	106,10
ErP efficiency ratio - electrical $\eta_{el,HS}$ ⁽⁴⁾	%	25,4	26,8	28,1	28,3
ErP efficiency ratio - thermal $\eta_{th,HS}$ ⁽⁴⁾	%	60,5	59,4	58,2	54,5
ErP efficiency ratio - total $\eta_{total,HS}$ ⁽⁴⁾	%	85,9	86,1	86,2	82,7
Room controller category ⁽⁴⁾		2	2	2	2
$P_{designh}$ ⁽⁴⁾	kW _{el}	15,6	18,0	20,1	22,4
Q_{HE} ⁽⁴⁾	kWh	25.861	28.298	29.995	33.184
P_{SB} electrical power requirement - standby ⁽⁴⁾	kW _{el}	0,05	0,05	0,05	0,05
Electrical power requirement - partial load ⁽⁴⁾	kW _{el}	0,74	0,74	0,74	0,74
$P_{el,max}$ Electrical power requirement - full load ⁽⁴⁾	kW _{el}	0,74	0,74	0,74	0,74
P_{stby_CHP} Thermal standing losses ⁽⁴⁾	kW _{th}	0,53	0,53	0,53	0,53
Electrical power requirement - standby ⁽⁴⁾	kW _{el}	0,05	0,05	0,05	0,05
$\eta_S = \eta_{son} - \Sigma(F1-F5)$ ⁽⁴⁾		125,0	131,7	138,2	139,3
Net output - electrical	kW _{el}	16,26	20,26	24,26	29,26

- 1) Performance data in accordance with ISO 3046/I-2002, tolerance +5% / -20%
- 2) Thermal performance data tolerance 8%
- 3) fpe-current = 2.8 displacement mix per DIN V 1859, DIN V 4701-10, GEG (attachment 4 to § 22 section 1) vaild from 11.2020
- 4) In accordance with EU Regulation 811/2013; 813/2013
- 5) Test bench measurement at 1 m interval in front of the CHP
- 6) Only when using the optional compensation (not required for neoTower® 50.0)
- 7) Exhaust air (without flue gas) does not have to be extracted "via the roof"
- 8) At a return temperature of 35 ° C and optimum operating conditions, tolerance 5%

Product designation	17.0, 21.0, 25.0, 30.0
Control cabinet	Fully equipped for seamless CHP unit operation with all necessary measurement and control equipment in bivalent operation. Dimensions control cabinet 600x600x200 mm; Approx. weight: 30-33 kg Connection cable CHP control cabinet standard 3m
Electrical connections	Supply line to control cabinet: 5x16mm ² Cu up to max. 50m (fuse 63 A slow blow) max. terminal area 35mm ²
	Temperature sensor cable: min. 2-08 JY(ST)Y up to 15 m length (2x1,5 mm ² up to 40 m length)
	Control cables pump: 3x1,5 mm ² ; RJ45 Patch cable in CHP connector
Reactive current compensation	Fixed compensation without reactors (detuned)
	Operating voltage: 230 / 400 Volt, 50 Hz
	Integrated capacitor contactor
	Discharging of approx 40 seconds must be considered
	Limiting temperature -10°C up to +35°C (average 24 h) +40°C (short-term max.)
	Steel housing 400x300x210mm (HxWxL)
Gas pressure [mbar / hPa]	Gas resting pressure before gas regulator: 20 - 50
	Flow pressure ≥ 18
Regulations and standards	Complies with the pertinent EU Directives for CE certification
Connections	Gas: 1" internal thread
	Heating supply line: 1" ball valve / PN 3.0
	Heating return line: 1" ball valve / PN 3.0
	Flue gas: DN80
	Exhaust air: DN160; accepted back pressure to be considered!
	Note: It is important to ensure that all terminals are connected via a flexible connection, in order to ensure vibration isolation.
	Residual pressure head secondary pump 0,7m
Method of operation	Mains parallel without emergency power, heat operated
	Use of electricity: Own requirement and infeed into the grid of the energy supply company, optional electricity-optimised modulation
	Heat usage automatically regulated in monovalent or bivalent operation with buffer tank; optionally heat-optimised modulation
Indicators and switches/buttons	Operation of the internal control and monitoring programs via central control unit (touchscreen for quick access to important functions)
	Back-lit graphical colour display with visualised system diagram and indicators for: temperature memory, motor, return line, hot water, interior, oil, flue gas, indicator for current power, water pressure, operation hours, generated energy, maintenance instructions and error notifications
	Switches/buttons: master switch, Emergency stop, Electric vehicle (Efv) charging data button, maintenance button
RMB/Report	Global live data tracking visualised in installation diagram, individual password protection, data logging with daily, weekly, monthly and annual report in graphical format, remote maintenance, remote monitoring, evaluation and reporting
Water quality	Motor circuit: 40% glycol, 60% water per VDI Regulation 2035. Operational pressure warm: 2.0 bar. Operational pressure cold: 1.8 bar. Primary pressure expansion vessel cold: 1.0 bar. Heating circuit ("secondary circuit"): water volume 14 l, free from mechanical impurities and as a minimum in accordance with quality requirements of the Group 2, VDI Regulation 2035 Conductivity < 100µS/cm Water hardness < 1° dH 8.2 > pH-Wert < 9 Deviations cause severe damages!

Deviating values depending on environmental and operating conditions.

Technical modification, design deviation and errors excepted.