



detail B
1:5





detail C
1:1



Schnitt A-A



1:20

BHKW vorne mit 21mm Abstand und seitlich
mit 75,5mm bzw. 65,5mm auf Schwingungsdämpfungsplatte ausrichten.
a = Federblockelement 3150414
Back = B (siehe Einzelheit C)
Die Befestigung der Federelemente auf dem Fundament erfolgt bauseitig.

Pos.	Art.-Nr.	Rev.	Titel	Stk.
	3241104	01	Positionierung BHKW 17.0 - 30.0 kW (el) auf Schwingungsdämpfungsplatte	
1	3191070	00	Schwingungsdämpfungsplatte 25.0 - 30.0kW RAL 7016	1
2	3240616		Federblockelemente-Satz 25.0-30.0 kW (el)	1
3	3070459	00	Senkkopfschraube ISO 10642 M12 x 30 8.8 vz	6

ATTENTION!
Unwinding data is for information purposes only! Information on outer dimensions and bending allowances do not dismiss the checker from inspection!

ind.	modification	date	name

Tolerances according:

weight: 1216,9

scale: 1:10

particularity:

material:

title: Positionierung BHKW 17.0 - 30.0 kW (el) auf Schwingungsdämpfungsplatte

This drawing must not be copied, forwarded, reproduced or otherwise used in any other way.

part number: 3241104

raw part number:

sheet: 1

1 sheets

origin:

modification:

current index:

material thickness: